

HVAC Assessment Report

California Schools Healthy Air, Plumbing, and Efficiency Ventilation Program
(CalShape - formerly AB 841)

Lighthouse Community School



Lighthouse Community School – 444 Hegenberger rd. Oakland CA 94621

Lodestar Community School – 645 105th ave Oakland Ca



PREPARED BY :



M2 Mechanical inc.
6115 Main Ave, Suite 18
Orangevale CA 95662
<http://www.m2-mechanical.com>



Alco Building Solutions
4320 Anthony Court, Unit 8
Rocklin, CA 95677
<http://www.m2-mechanical.com>



Steve Toy PE
V 530-207-3351
C 530-392-2307
steve@ecd-llc.net



Table Of Contents

| | |
|--|-----------|
| ABBREVIATIONS AND ACRONYMS..... | 3 |
| LICENSES AND CERTIFICATIONS | 3 |
| 1.0 EXECUTIVE SUMMARY | 4 |
| 1.1 BACKGROUND | 4 |
| 1.2 PROJECT GOALS AND GUIDELINES..... | 4 |
| 1.3 BENEFITS TO THE SCHOOL DISTRICT | 4 |
| 1.4 ASSESSMENT SITE SUMMARY | 5 |
| 2.0 LIGHTHOUSE COMMUNITY SCHOOL..... | 6 |
| 2.1 CAMPUS DESCRIPTION | 6 |
| 2.2 SITE MAPS..... | 6 |
| 2.3 EQUIPMENT LOCATIONS | 7 |
| 2.4 HVAC EQUIPMENT TYPES | 8 |
| 3.0 LIGHTHOUSE COMMUNITY SCHOOL..... | 9 |
| 3.1 CAMPUS DESCRIPTION | 9 |
| 3.2 SITE MAPS..... | 9 |
| 3.3 EQUIPMENT LOCATIONS | 10 |
| 3.4 HVAC EQUIPMENT TYPES | 11 |
| 3.5 DEFICIENCIES AND RECOMMENDATIONS | 12 |
| 3.6 INSTALL NETWORK-BASED CONTROLS PLATFORM WITH CO2 AND DCV | 13 |
| 3.7 OLD EQUIPMENT NEEDING REPLACEMENT | 14 |
| 3.8 ADVANCED CONTROL OPTIONS FOR PACKAGED ROOFTOP UNITS | 14 |
| 4.0 METHODOLOGY..... | 16 |
| 5.0 APPENDICES | 18 |
| 5.1 APPENDIX A – ASSESSMENT SUMMARY TABLE..... | 18 |
| 5.2 APPENDIX B – EQUIPMENT INFORMATION – FILTERS AND BELT SIZES..... | 19 |
| 5.3 APPENDIX C – CERTIFICATIONS | 20 |
| 5.4 APPENDIX D – TEST DATA | 21 |



Abbreviations and Acronyms

| | |
|-----------------|---|
| ASHREA | American Society of Heating Refrigeration and Air-Conditioning Engineers. |
| CO2 | Carbon Dioxide |
| DCV | Demand control ventilation |
| DDC | Direct Digital Control |
| Ft ² | Square foot, square feet, a measurement of area |
| CFM | Cubic feet Per Minute, a measure of air volume |
| HVAC | Heating, ventilation, and air-conditioning |
| MERV | Minimum Efficiency Reporting Value |
| EUL | Equipment Expected Useful Life. Source (www.ashrae.org) |
| CalSHAPE | California Schools Healthy Air, Plumbing, and Efficiency Program |
| LEA | Local Education Agency |
| OSA | Outside Air |
| WC | Water column |

Licenses and Certifications

| Personnel and Certifications | Company | License Agency | License / Certification Number |
|------------------------------|-------------------------------|-------------------------------------|--------------------------------|
| Qualified Testing Personnel | M2 Mechanical | ICB/TABB | MAT11315983T |
| Certified TAB Technician | M2 Mechanical | ICB/TABB | BB1288589T |
| Contractor | Alco Building Solutions | Contractor State License Board CSLB | 831145 |
| Licensed Professional | Engineering Consulting Design | State Of California | M34941 |

Engineering Consulting Design

Name: _____

Sign: _____

Date: _____

Stamp:



1.0 Executive Summary

1.1 Background

Research indicates that many California classrooms suffer from poor ventilation, which negatively impacts students' health, academic performance, and attendance. HVAC systems play a crucial role in improving indoor air quality by removing pollutants and regulating CO₂ levels through proper air exchange. However, these systems can also contribute to increased energy consumption. Factors such as filter type, system design, and ventilation volume all influence both energy use and air quality. A thorough analysis of these elements can help school districts develop strategies that enhance air quality while minimizing energy costs.

In response to these challenges, California enacted the Healthy Schools, Healthy Air, Healthy Recovery Bill (AB-841) in 2020, which provides funding for schools to upgrade their ventilation systems. This initiative, now known as the California Schools Healthy Air, Plumbing, and Efficiency Program (CalSHAPE), provides funding for HVAC evaluations, filter replacements, and the installation of CO₂ sensors in classrooms.

1.2 Project Goals and Guidelines

M2 Mechanical Inc. was contracted by Alco Building Solutions to conduct an HVAC assessment as part of the CalSHAPE grant initiative. Our team performed a comprehensive evaluation of the HVAC systems across the Lighthouse Community School District campus, focusing on their ability to meet modern indoor air quality and ventilation standards.

Key assessment areas included:

- HVAC inspection, testing, and maintenance to meet ventilation standards.
- Filter replacement and upgrades for better air quality.
- Repairs or replacements of non-functioning HVAC units.
- Compliance with current outside air ventilation rates
- Carbon dioxide monitoring to ensure proper airflow and CO₂ reduction in classrooms.
- Overall age and condition of HVAC units

Many older HVAC units were not originally designed to support MERV 13 filtration, nor can they efficiently handle the increased heating and cooling demands required for enhanced outside air ventilation. In cases where systems are nearing the end of their useful life, upgrades may not be a cost-effective solution. While the average lifespan of HVAC equipment is 15-20 years, recommendations for replacement must also consider maintenance history, usage levels, refrigerant type and equipment efficiency and design.


1.3 Benefits to the School District

The findings in this report provide valuable insights for the School District to make informed decisions regarding HVAC infrastructure investments and maintenance planning. Implementing these recommendations will enhance indoor air quality, support student well-being, and optimize energy efficiency. Furthermore, M2 Mechanical Inc. remains committed to supporting the district throughout the implementation process, offering continued guidance and expertise to ensure the success of the proposed improvements.



1.4 Assessment Site Summary

The graph and table below summarize the key findings from the HVAC assessment conducted at Lighthouse Community School. Detailed information for each individual HVAC unit is provided in the appendix, which includes summary tables and data sheets. An overview of the common types of HVAC equipment found at the school is presented in Section 2.4, while Section 2.5 outlines typical deficiencies frequently observed across the campus.



Lighthouse Community School has 31 HVAC units, most of which are around 16 years old and have exceeded their expected useful life. The district has done an excellent job maintaining the equipment, with few reported issues and only a small number of economizers in need of repair. However, due to the age of the systems, they are inherently less efficient, more susceptible to failure, and increasingly expensive to maintain. Rather than continuing to invest in outdated units, a replacement strategy is recommended—one that incorporates modern features such as Demand Control Ventilation (DCV), which adjusts airflow based on occupancy to reduce energy use and improve indoor air quality by lowering CO₂ levels in classrooms and shared areas. All existing units support MERV 13 filters, and using 2-inch thick versions is advised for optimal performance. Upgrading to new systems with these advanced capabilities will enhance comfort, efficiency, and sustainability throughout the school.

Estimated Cost for controls and HVAC replacement at both sites.

| Location | Overall Project Investment | Unit Count | Tons | Estimated Cost Per Unit/Ton | Total Cost |
|------------------------------------|--|------------|------|-----------------------------|---------------------|
| Lode Star | HVAC Unit Replacement | 15 | 54 | \$6,000 | \$ 324,000 |
| Lode Star | Install Network-Based Wireless Thermostats With DCV Capability | | 41 | \$2,000 | \$ 82,000 |
| Lighthouse HS | HVAC Unit Replacement | 12 | 69 | \$6,000 | \$ 414,000 |
| Lighthouse ES | HVAC Unit Replacement | 19 | 96 | \$6,000 | \$ 576,000 |
| Lighthouse HS | Install Network-Based Wireless Thermostats With DCV Capability | 12 | | \$2,000 | \$ 24,000 |
| Lighthouse ES | Install Network-Based Wireless Thermostats With DCV Capability | 19 | | \$2,000 | \$ 38,000 |
| Total Additional Investment | | | | | \$ 1,458,000 |


2.3 Equipment Locations

The map below shows the HVAC equipment locations. The different colors indicate the different types of units. This particular school only has various different tonnage of Trane Package units.

| Legend | | |
|--|----------|--|
| Description | Quantity | |
| ■ Package Units | 31 | |

Light House Community

ABS Count:31
 Map Count:31
 Actual Count:31



2.4 HVAC Equipment Types

Equipment Types

Trane Package Units: #1 -#31



MEV 16 Filters, Zone control board, Ducting with Bypass Damper



Lodestar HVAC Assessment Report




3.0 Lighthouse Community School

3.1 Campus Description


Lighthouse Community School is located at – 444 Hegenberger rd. Oakland CA 94621. This campus is made up of one permanent concrete structure.

3.2 Site Maps

Floor Plan- Lodestar Building 1 (K-5)



Floor Plan- Lodestar Building 2 (6-8)




Lodestar Building 2

Floor Plan- Lodestar Building 3 (9-10)



FLOOR PLAN - SECOND FLOOR




Lodestar Building 3



3.3 Equipment Locations

The map below shows the HVAC equipment locations. The different colors indicate the different types of units. This particular school only has various different tonnage of Trane Package units.



3.4 HVAC Equipment Types

Equipment Types

Carrier Package Units: #1 -#19



Lennox Package Units: #20 -#39



Split Systems Units: #40 -#41



3.5 Deficiencies and Recommendations

Filtration

All of the HVAC units on this campus are currently utilizing MERV 16 filters, which exceed the ASHRAE recommendations for improved indoor air quality.

Outside Air

Malfunctioning or undersized outside air dampers resulted in 16 units did not meet ventilation requirements based on ASHRAE 62.1 or Table 120.1-A of the 2019 Title 24 California Building Energy Efficiency Standards.

Economizer Component Degradation in Aged Rooftop Units

Mechanical rooftop units nearing or past their expected service life often experience high failure rates in economizer components. Common issues include corroded dampers, worn linkages, and failed actuators—primarily due to age, wear, and environmental exposure.

While many of these units require economizer repairs, the advanced age of the equipment raises concerns about cost-effectiveness. Repairs may offer limited value as other components are also likely to fail soon.

Recommendation: Evaluate the cost-benefit carefully. In many cases, replacing the entire unit may be more prudent than investing in short-term fixes. If the equipment is less than 15 years old and in good functioning shape repairing or adding economizers is recommended.

Demand Control Ventillation (DCV)



The HVAC systems at this school are currently managed through a standalone thermostats, which provides basic operational control. However, the lack of CO₂ monitoring capabilities limits the system’s ability to implement Demand-Controlled Ventilation (DCV) — a critical strategy for balancing indoor air quality (IAQ) with energy efficiency.

To address this limitation, it is strongly recommended that the control system be upgraded to include: CO₂ sensors in key occupied zones and DCV logic integration within the building automation system.

By incorporating these enhancements, the system would be capable of modulating ventilation rates in response to real-time occupancy levels, thereby:

- Reducing unnecessary outdoor air intake during low-occupancy periods.
- Improving IAQ by increasing ventilation when CO₂ concentrations rise.
- Lowering energy consumption associated with conditioning excessive outdoor air.

Implementing DCV not only aligns with best practices for energy-efficient building operation but also supports occupant health and compliance with evolving indoor air quality standards.



3.6 Install Network-Based Controls Platform With CO2 and DCV

Definition and Features: A network-based controls platform involves connecting HVAC systems and other building management systems (BMS) to a central network, enabling centralized monitoring and control. This platform is often managed through a building automation system (BAS).

Key Benefits:

Centralized Control and Monitoring:

- Facility managers can control and monitor all HVAC units and other systems (like lighting and security) from a single interface. This centralized approach simplifies management and improves operational efficiency.
- For schools, this means that all classrooms and common areas can be managed from a single location, reducing the need for individual adjustments.

Enhanced Energy Management:

- Network-based controls provide detailed analytics and reporting on energy usage. Managers can identify inefficiencies and adjust settings to optimize energy consumption across the entire facility.
- Automated controls can adjust HVAC settings based on occupancy, time of day, or other predefined conditions, ensuring optimal energy use without manual intervention.

Improved Maintenance and Diagnostics:

- The system can alert maintenance staff to issues before they become major problems. Predictive maintenance features can analyze data trends to anticipate and prevent equipment failures.
- Remote diagnostics allow for quick identification and resolution of issues, minimizing downtime and maintenance costs.

Scalability and Flexibility:

- Network-based systems can easily scale to accommodate additional HVAC units or other systems as needed. This flexibility is crucial for growing schools or campuses with varying demands.

Enhanced Indoor Air Quality (IAQ):

- Integrated controls can ensure proper ventilation by adjusting outside air intake based on occupancy and air quality sensors, maintaining a healthy indoor environment.

Wireless thermostats and network-based controls platforms significantly enhance the management and efficiency of HVAC systems in schools. They provide remote access, improve energy savings, integrate with smart home devices, and offer centralized control and monitoring, leading to optimized energy use, better indoor air quality, and enhanced maintenance capabilities. These technologies are valuable tools for creating a comfortable, healthy, and energy-efficient learning environment.

3.7 Old Equipment Needing Replacement

Aging HVAC systems (10–15 yrs for A/C, 15–20 yrs for furnaces) often decline in efficiency and performance, leading to higher energy costs and comfort issues. While maintenance can extend system life, age alone isn't the only factor to consider.

Key Replacement Indicators:

- High Repair Frequency: Annual repairs >50% of replacement cost.
- Inefficiency: Outdated SEER/AFUE ratings, rising utility bills.
- Performance Issues: Inconsistent temps, poor humidity control, unusual noise.
- Air Quality Problems: Dust, odors, or mold.

Recommendation: If multiple factors are present, replacement is typically more cost-effective and reliable than ongoing repairs. New systems can improve comfort, air quality, and energy savings.

3.8 Advanced Control Options for Packaged Rooftop Units

This section evaluates four advanced control strategies for packaged single-zone rooftop units, assessing their energy savings against a baseline:

- Air-side economizers
- Supply-fan speed controls
- Cooling capacity controls
- Demand-controlled ventilation

Air-Side Economizer Controls

Air-side economizers reduce mechanical cooling energy by using cool outdoor air (OA) when conditions are favorable. They modulate OA dampers to exceed minimum ventilation rates, partially or fully offsetting mechanical cooling needs.

Control Strategies:

- Fixed Dry-Bulb / Enthalpy: Compares OA temperature or enthalpy to a fixed setpoint (e.g., 55–75°F or ~28 Btu/lb). If OA is below the setpoint, economizing is enabled.
- Differential Dry-Bulb / Enthalpy: Compares OA to return-air conditions. Economizer operates when OA is cooler or less enthalpic.

Operational Modes:

- Integrated: Uses OA and mechanical cooling simultaneously. Maximizes energy savings by engaging mechanical cooling only as needed.
- Nonintegrated: OA is used alone. Mechanical cooling activates only when OA cannot meet the full load.



DRAFT

4.0 Methodology

Outside Air Requirements

The outside air requirements for the spaces were determined using the 2019 title 24 values from the table below (0.38 CFM/ft²). Each area was measured and the values were multiplied by 0.38 to determine the CFM of fresh air required.

| Standard | Method | 15 People | 25 People | 35 People |
|----------------------------|--|-----------|-----------|-----------|
| ASHRAE 62.1 2019 | 10 CFM/person + 0.12 CFM/ft ² | 258 CFM | 358 CFM | 458 CFM |
| California T24 (2019) | 15 CFM/person | 225 CFM | 375 CFM | 525 CFM |
| California Title 24 (2019) | 0.38 CFM/ft ² | 342 CFM | 342 CFM | 342 CFM |

} Use Larger



Ventilation Rates

Air Velocity for the return grilles was measured using a Evergreen differential pressure sensor and a velocity grid.

Return air grille flow is calculated using the following formula:



$$\text{Airflow (cfm)} = \text{Grille Area (sq.in)} \div 144 \times \text{Face Velocity (fpm)}$$

Supply airflow was measured using the duct traverse method or by using a flow hood. The same principle applies for the supply registers, CFM=Area x Velocity.



Measuring Static Pressures

Static pressure measurements were taken in specific areas on the different types of equipment to determine if more restrictive MERV 13 filters would restrict airflow and cause the equipment to malfunction.





Ventilation Rate

Volumes of the rooms (LxWxH) were measured with a laser measuring tool.

$$ACH = [\text{Equivalent Outdoor air flow (CFM)} \times 60 \text{ (minutes)}] / [\text{Room Volume (ft}^3\text{)}]$$

Equivalent Outdoor air = [% Outside Air in Supply (%OA) + Equivalent Filtered non outside as outside air (OA) air calculated by MERV Filter type] (Sample Calculation in APPENDIX)

TABLE 120.1-A– Minimum Ventilation Rates

| Standard | Method | 15 People | 25 People | 35 People |
|----------------------------|--|-----------|-----------|-----------|
| ASHRAE 62.1 2019 | 10 CFM/person + 0.12 CFM/ft ² | 258 CFM | 358 CFM | 458 CFM |
| California T24 (2019) | 15 CFM/person | 225 CFM | 375 CFM | 525 CFM |
| California Title 24 (2019) | 0.38 CFM/ft ² | 342 CFM | 342 CFM | 342 CFM |

Use Larger

| Category | Occupancy | Total Outdoor Air Rate 1 Rt (cfm/ft ²) | Min Ventilation Air Rate for DCV R _a (cfm/ft ²) | Air Class | Notes |
|-------------------------------|---------------------------------|--|--|-----------|-------|
| Educational Facilities | | | | | |
| | Daycare (through age 4) | 0.21 | 0.15 | 2 | |
| | Daycare sickroom | 0.15 | | 3 | |
| | Classrooms (ages 5-8) | 0.38 | 0.15 | 1 | |
| | Classrooms (age 9 -18) | 0.38 | 0.15 | 1 | |
| | Lecture/postsecondary classroom | 0.38 | 0.15 | 1 | F |
| | Lecture hall (fixed seats) | - | 0.15 | 1 | F |
| | Art classroom | 0.15 | | 2 | |
| | Science laboratories | 0.15 | | 2 | |
| | University/college laboratories | 0.15 | | 2 | |
| | Wood/metal shop | 0.15 | | 2 | |
| | Computer lab | 0.15 | | 1 | |
| | Media center | 0.15 | | 1 | A |
| | Music/theater/dance | 1.07 | 0.15 | 1 | F |
| | Multiuse assembly | 0.5 | 0.15 | 1 | F |



5.0 Appendices

5.1 Appendix A – Assessment Summary Table

4.1 – Assessment Summary Table

| Equipment Information | | | | | | | | Areas With Deficiencies | | | | |
|-----------------------|-----------------|-----------|---|------------------------|---------------------------------|-----------------------|---------------------------|-------------------------|-------------|-------------|------------------|-------------|
| HVAC Unit Number | Room # | Age (Yrs) | Equipment Meets Minimum Ventilation Requirements ¹ | Is there an Economizer | Economizer Functioning Properly | Type of HVAC Controls | DCV Retrofit Recommended? | Due for Replacement | Filteration | Outside Air | Economizer & DCV | Maintenance |
| 1 | N121 | 16 | No | Yes | No | Local Thermostat | Yes | ✓ | ✓ | X | X | ✓ |
| 2 | Hallway | 16 | Yes | Yes | Yes | Local Thermostat | Yes | ✓ | ✓ | ✓ | ✓ | ✓ |
| 3 | 101&102 | 16 | No | Yes | No | Local Thermostat | Yes | ✓ | ✓ | X | X | ✓ |
| 4 | 105-106-108-143 | 16 | Yes | Yes | Yes | Local Thermostat | Yes | ✓ | ✓ | ✓ | ✓ | ✓ |
| 5 | N142-Science | 16 | Yes | Yes | Yes | Local Thermostat | Yes | ✓ | ✓ | ✓ | ✓ | ✓ |
| 6 | N104 | 16 | Yes | Yes | Yes | Local Thermostat | Yes | ✓ | ✓ | ✓ | ✓ | ✓ |
| 7 | 139-141 | 16 | No | Yes | Yes | Local Thermostat | Yes | ✓ | ✓ | X | ✓ | ✓ |
| 8 | 118-140-119 | 16 | No | Yes | No | Local Thermostat | Yes | ✓ | ✓ | X | X | ✓ |
| 9 | 116-117-119 | 16 | No | Yes | No | Local Thermostat | Yes | ✓ | ✓ | X | X | ✓ |
| 10 | 109-110 | 16 | No | Yes | Yes | Local Thermostat | Yes | ✓ | ✓ | X | ✓ | ✓ |
| 11 | 128-132-133 | 16 | No | Yes | No | Local Thermostat | Yes | ✓ | ✓ | X | X | ✓ |
| 12 | N121 | 16 | No | Yes | No | Local Thermostat | Yes | ✓ | ✓ | X | X | X |
| 13 | 123-124 | 16 | No | Yes | Yes | Local Thermostat | Yes | ✓ | ✓ | X | ✓ | ✓ |
| 14 | Hallway | 16 | No | Yes | No | Local Thermostat | Yes | ✓ | ✓ | X | X | ✓ |
| 15 | 110-111 | 16 | No | Yes | No | Local Thermostat | Yes | ✓ | ✓ | X | X | ✓ |
| 16 | 211-212 | 16 | No | Yes | No | Local Thermostat | Yes | ✓ | ✓ | X | X | ✓ |
| 17 | 112-113 | 16 | No | Yes | No | Local Thermostat | Yes | ✓ | ✓ | X | X | ✓ |
| 18 | 129-130-131-133 | 16 | No | Yes | No | Local Thermostat | Yes | ✓ | ✓ | X | X | ✓ |
| 19 | 213-215 | 16 | No | Yes | No | Local Thermostat | Yes | ✓ | ✓ | X | X | ✓ |
| 20 | 216 | 16 | Yes | Yes | Yes | Local Thermostat | Yes | ✓ | ✓ | ✓ | ✓ | ✓ |
| 21 | 114 | 16 | Yes | Yes | No | Local Thermostat | Yes | ✓ | ✓ | ✓ | X | ✓ |
| 22 | 138-140-141-142 | 16 | No | Yes | Yes | Local Thermostat | Yes | ✓ | ✓ | X | ✓ | ✓ |
| 23 | 217-218 | 16 | No | Yes | No | Local Thermostat | Yes | ✓ | ✓ | X | X | ✓ |
| 24 | 219-220 | 16 | No | Yes | Yes | Local Thermostat | Yes | ✓ | ✓ | X | ✓ | ✓ |
| 25 | 106-146-147-148 | 16 | Yes | Yes | No | Local Thermostat | Yes | ✓ | ✓ | ✓ | X | ✓ |
| 26 | Hallway | 16 | Yes | Yes | Yes | Local Thermostat | Yes | ✓ | ✓ | ✓ | ✓ | ✓ |
| 27 | 221-222 | 16 | No | Yes | No | Local Thermostat | Yes | ✓ | ✓ | X | X | ✓ |
| 28 | 102-107-115-116 | 16 | No | Yes | No | Local Thermostat | Yes | ✓ | ✓ | X | X | ✓ |
| 29 | 109-Hallway | 16 | Yes | Yes | Yes | Local Thermostat | Yes | ✓ | ✓ | ✓ | ✓ | ✓ |
| 30 | 121-122 | 16 | No | Yes | No | Local Thermostat | Yes | ✓ | ✓ | X | X | ✓ |
| 31 | 201-202-204-205 | 16 | No | Yes | No | Local Thermostat | Yes | ✓ | ✓ | X | X | ✓ |



5.2 Appendix B – Equipment Information – Filters and Belt Sizes



HVAC Equipment Details - Site Summary

| General Equipment Information | | | | | | | | | | | | | | | | | |
|-------------------------------|-----------------|------------------|-------------|---|------------------|-------|--|------------|------|---------|-------------------|-------------------------|---------------|---------------|---------------|---------------|-----------|
| General Equipment Information | | | | Package Unit / Condenser / Chiller (Outdoor Unit) | | | Furnace / Air Handler / Boiler (Indoor Unit) | | | | Filters and Belts | | | | | | |
| HVAC Unit # | Room # | Equipment Type | Age (years) | Cooling Size (Tons) | Heating (kBtu/h) | Make | Model # | Serial # | Make | Model # | Serial # | Recommended MERV Rating | Filter 1 Qty. | Filter 1 Size | Filter 2 Qty. | Filter 2 Size | Belt Size |
| --- | --- | --- | 2025 | --- | --- | --- | NOT A UNIT | --- | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| --- | --- | --- | 2025 | --- | --- | --- | NOT A UNIT | --- | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| --- | --- | --- | 2025 | --- | --- | --- | NOT A UNIT | --- | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| --- | --- | --- | 2025 | --- | --- | --- | NOT A UNIT | --- | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| 5 | MRR | Package Gas/Elec | 16 | 9 | 138 | Trane | YSC102E4RHAD001 | 924101604L | --- | --- | --- | 13 | 4 | 20x25x2 | --- | N/A | A-3 |
| 6 | Other (Specify) | Package Gas/Elec | 16 | 13 | 150 | Trane | YCH150E4LOAA | 919100354D | --- | --- | --- | 13 | 4 | 20x25x2 | 2 | 20x20x2 | A-6 |
| 7 | Classroom | Package Gas/Elec | 16 | 6 | 80 | Trane | YSC072ERLACNC | 924101725L | --- | --- | --- | 13 | 4 | 16x25x2 | --- | N/A | A-3 |
| 8 | Classroom | Package Gas/Elec | 16 | 3 | 60 | Trane | YSC036E4RLA001 | 925100470L | --- | --- | --- | 13 | 2 | 20x30x2 | --- | N/A | A-2 |
| 9 | Classroom | Package Gas/Elec | 16 | 4 | 80 | Trane | YSC048E4RZAD01 | 921181702L | --- | --- | --- | 13 | 2 | 20x30x2 | --- | N/A | A-2 |
| 10 | Classroom | Package Gas/Elec | 16 | 4 | 80 | Trane | YSC048E4RLA001 | 924101415L | --- | --- | --- | 13 | 2 | 20x30x2 | --- | N/A | A-2 |
| 11 | Classroom | Package Gas/Elec | 16 | 3 | 60 | Trane | YSC036E4RLA001 | 925100456L | --- | --- | --- | 13.0 | 2 | 20x30x2 | --- | N/A | A-2 |
| 12 | Classroom | Package Gas/Elec | 16 | 4 | 80 | Trane | YSC048E4RLA001 | 924101155L | --- | --- | --- | 13.0 | 2 | 20x30x2 | --- | N/A | A-2 |
| 13 | Classroom | Package Gas/Elec | 16 | 5 | 80 | Trane | YSC048E4RLA001 | 924101556L | --- | --- | --- | 13 | 2 | 20x30x2 | --- | N/A | A-2 |
| 14 | Classroom | Package Gas/Elec | 16 | 4 | 80 | Trane | YSC048E4RLA001 | 924101714L | --- | --- | --- | 13 | 2 | 20x30x2 | --- | N/A | A-2 |
| 15 | Classroom | Package Gas/Elec | 16 | 6 | 80 | Trane | YSC072ERLACNC | 924100991L | --- | --- | --- | 13 | 4 | 16x25x2 | --- | N/A | A-3 |
| 16 | MRR | Package Gas/Elec | 16 | 9 | 138 | Trane | YSC102E4RHAD001 | 924101618L | --- | --- | --- | 13 | 4 | 20x25x2 | --- | N/A | A-2 |
| 17 | Classroom | Package Gas/Elec | 16 | 3 | 60 | Trane | YSC036E4RLA001 | 924101000L | --- | --- | --- | 13.0 | 2 | 20x30x2 | --- | N/A | A-2 |
| 18 | Other (Specify) | Package Gas/Elec | 16 | 10 | 110 | Trane | YSC120E4RLA001 | 924101204L | --- | --- | --- | 13.0 | 4 | 16x25x2 | --- | N/A | A-3 |
| 19 | Classroom | Package Gas/Elec | 16 | 3 | 60 | Trane | YSC036E4RLA001 | 924100896L | --- | --- | --- | 13 | 2 | 20x30x2 | --- | N/A | A-2 |
| 20 | Classroom | Package Gas/Elec | 16 | 5 | 80 | Trane | YSC036E4RLA001 | 924101110L | --- | --- | --- | 13 | 2 | 20x30x2 | --- | N/A | A-2 |
| 21 | Classroom | Package Gas/Elec | 16 | 3 | 60 | Trane | YSC036E4RLA001 | 924101704L | --- | --- | --- | 13 | 2 | 20x30x2 | --- | N/A | A-2 |
| 22 | Classroom | Package Gas/Elec | 16 | 4 | 80 | Trane | YSC048E4RLA001 | 924101166L | --- | --- | --- | 13 | 2 | 20x30x2 | --- | N/A | A-2 |
| 23 | Classroom | Package Gas/Elec | 16 | 5 | 80 | Trane | YSC060E4RHAD01 | 924101613L | --- | --- | --- | 13.0 | 2 | 20x30x2 | --- | N/A | A-2 |
| 24 | Classroom | Package Gas/Elec | 16 | 4 | 80 | Trane | YSC048E4RLA001 | 924101726L | --- | --- | --- | 13.0 | 2 | 20x30x2 | --- | N/A | A-2 |
| 25 | Classroom | Package Gas/Elec | 16 | 6 | 80 | Trane | YSC072ERLACNC | 924101018L | --- | --- | --- | 13 | 4 | 16x25x2 | --- | N/A | A-3 |
| 26 | Classroom | Package Gas/Elec | 16 | 4 | 80 | Trane | YSC048E4RLA001 | 924101180L | --- | --- | --- | 13 | 2 | 20x30x2 | --- | N/A | A-2 |
| 27 | Classroom | Package Gas/Elec | 16 | 5 | 80 | Trane | YSC060E4RHAD01 | 924101088L | --- | --- | --- | 13 | 3 | 20x30x3 | --- | N/A | A-2 |
| 28 | Classroom | Package Gas/Elec | 16 | 6 | 80 | Trane | YSC072ERLACNC | 924100977L | --- | --- | --- | 13 | 4 | 16x25x2 | --- | N/A | A-3 |
| 29 | Classroom | Package Gas/Elec | 16 | 5 | 80 | Trane | YSC060E4RHAD01 | 924101044L | --- | --- | --- | 13.0 | 2 | 20x30x2 | --- | N/A | A-2 |
| 30 | Other (Specify) | Package Gas/Elec | 16 | 13 | 138 | Trane | YCH150E4LOAA | 923100749D | --- | --- | --- | 13.0 | 4 | 20x25x2 | 2 | 20x20x2 | A-6 |
| 31 | Classroom | Package Gas/Elec | 16 | 3 | 60 | Trane | YSC036E4RLA001 | 924101014L | --- | --- | --- | 13 | 2 | 20x30x2 | --- | N/A | A-2 |
| 32 | Classroom | Package Gas/Elec | 16 | 3 | 60 | Trane | YSC036E4RLA001 | 924100958L | --- | --- | --- | 13 | 2 | 20x30x2 | --- | N/A | A-2 |
| 33 | Classroom | Package Gas/Elec | 16 | 3 | 60 | Trane | YSC036E4RLA001 | 924101716L | --- | --- | --- | 13 | 2 | 20x30x2 | --- | N/A | A-2 |
| 34 | Classroom | Package Gas/Elec | 16 | 6 | 80 | Trane | YSC072ERLACNC | 924100996L | --- | --- | --- | 13 | 4 | 16x25x2 | --- | N/A | A-3 |
| 35 | Classroom | Package Gas/Elec | 16 | 6 | 80 | Trane | YSC072ERLACNC | 924101004L | --- | --- | --- | 13.0 | 4 | 16x25x2 | --- | N/A | A-3 |



5.3 Appendix C – Certifications

DRAFT



5.4 Appendix D – Test Data

| System Components | Outside Air and Economizers | Controls and DCV | Schedule and Setpoints | |
|---|--|---|---|--|
| Unit Type: Package Gas Heat Economizer Present in system: Yes Econ Functioning: No Powered Exhaust Present: No Power Exhaust Function: No | Heating Type: Gas Heat Cooling Type: Compressor Air Conditioning Cooling Stages: 2 Heating Stages: 1 Equipment Age: 15 | Type of OSA Damper: Powered Vent Occupancy Category (Room Type): HH Actual Occupancy: 25 Floor Area (sq ft): 1,144 Required OSA (CFM) (Design): 900 | Controls Access: Local Thermostat Controls Functioning Correctly: Hard Error Existing CoD (DCV): No DCV Upgrade Feasible: Hard Error | Occupied Heating: 6:00:00AM - 6:00:00PM Occupied Cooling: 6:00:00AM - 6:00:00PM Unoccupied Heating: 5:00:00PM - 5:00:00PM Unoccupied Cooling: 5:00:00PM - 5:00:00PM |
| Equipment Nameplate Data | | | | |
| Package Unit / Condenser / Chiller (Outdoor Unit) Manufacturer: Inco Mtg. Date: 2009 Model Number: HVC2024HWA0025 Serial Number: 9241010044 Cooling Ton: 3 Refrigerant Type: R-22 | Data For Both Heating Input Capacity (kBtu/h): 128 Heating Output Capacity (kBtu/h): 122 Cooling Output Capacity (kBtu/h): 100 Nameplate Max Ext SP: 0.780 Volts: 480 Phase: 3 | Furnace/Air Handler / Boiler (Indoor Unit) Manufacturer: Inco Model Number: 2009 Serial Number: 9241010044 Can Filter Rack: N/A Filter Rack: N/A Spares: 4 | Filtration Quantity: 4 Size: 20x25x2 Current MERV: 16 Filter 1: 4 Filter 2: N/A Filter 3: N/A Filter 4: N/A Filter Count: 4 MERV 13 UPGRADE? #N/A | |
| Motor Data Direct/Belt Drive: Belt Constant / Variable: No Manufacturer: GE Motor RPM: 1725 Hp: 2 Amps: 3 Volts: 480 Phase: 3 Service Factor: 1 Frame Size: 143T Motor Sheave Model: 8000 Shaft Diameter (in): 1 Pitch Diameter (in): 5.57 Fan Speed Tap Setting: Hard Low | Fan Data Fan Sheave Model: 8000 Shaft Diameter (in): 1 Shaft Centerline (in): 20 Fan RPM: 880 Grooves (# Belts): 1 Belt Size: A-35 Economizer: The system was installed before the Model of Actuator High Limit Type: Fixed Enthalpy + Fixed Dry Bulb High Limit Setting: 65 Min Position (%): 10% Low Spd Min Pos (%): (CO2) Setpoint (ppm): 800 | Pre Mod Measurements (As Found) Supply Design (CFM): 3470 Supply CFM (Sum Term): 3470 Supply CFM (Pilot): 0 Return Design (CFM): 3040 Return CFM (Sum Term): 2887 Return CFM (Pilot): 0 Estimated OSA (Sup-Req): 851 Measured OSA CFM: 821 Motor RPM (Actual): 1725 Fan RPM (Actual): 880 Supply SP (inwc): 0.1470 Return SP (inwc): -0.0927 Filter DP: 0.0006 Coil DP: 0.0000 Total Sp. (Fan): 0.0000 Ext. Static Pressure (Actual): 0.340 Building Press. (inwc): 0.000 Motor Amps (Actual): 3 Motor Input Power (BHP): 3 | Post Mod Measurements (As Left) Supply Design (CFM): 3470 Supply CFM (Sum Term): 3470 Supply CFM (Pilot): 0 Return Design (CFM): 3040 Return CFM (Sum Term): 2887 Return CFM (Pilot): 0 Estimated OSA (Sup-Req): 851 Measured OSA CFM: 821 Motor RPM (Actual): 1725 Fan RPM (Actual): 880 Supply SP (inwc): 0.1470 Return SP (inwc): -0.0927 Filter DP: 0.0006 Coil DP: 0.0000 Total Sp. (Fan): 0.0000 Ext. Static Pressure (Actual): 0.340 Building Press. (inwc): 0.000 Motor Amps (Actual): 3 Motor Input Power (BHP): 3 | Results Required Minimum OSA (CFM): 1050 Equipment Max External Static Pressure: 0.70 Measured External Static Pressure: 0.24 % OSA (Current OSA/Required OSA): 81% Current OSA Damper Position: 10% CFM Target: 297 CFM sqft: 1.62 Analysis Required Outside Air Ventilation (CFM): 1050 Actual Measured Outside Air Ventilation (CFM): 821 OSA Ventilation Pass/Fail: Fail MERV Rating Target: 13 Actual Achievable MERV Rating for Unit: 13 Filtration Pass/Fail: #N/A Setpoints and Schedules Optimized for Energy Efficiency? No Is Network Based Controls Needed? No Does the Unit Currently Have DCV?: Yes Repair/Replace: Replace Additional Investment in this Equipment Recommended?: No |
| Assessed Areas Filters & Airflow Distribution & Pressurization: Belt Replaced Outside Air: No Adjustment Possible Economizer & DCV: No Adjustment Possible Operational Controls: Replaced Belt General Maintenance: Replaced Belt Repair or Replacement Recommendation: Replace | Repairs and Adjustments The system was installed before the Model of Actuator Fixed Enthalpy + Fixed Dry Bulb High Limit Setting: 65 Min Position (%): 10% Low Spd Min Pos (%): (CO2) Setpoint (ppm): 800 | Remaining Deficiencies No Remaining Deficiencies Outdoor air controller is broken (no power or has fault) Routine Light Controls With well, CO2 & CO Clean condenser and evaporator coils Due to high repair costs, increased operational expenses, fre | Remaining Deficiency Notes No Additional Notes No contingency funds available for repairs. No contingency funds available for repairs. No contingency funds available for repairs. No contingency funds available for repairs. Due to high repair costs, increased operational expenses, frequent maintenance requirements, decreased reliability, reduced environmental efficiency, and diminished performance | |



DRAFT